



CERTIFICATE OF ANALYSIS

W0905827

[]

DAVID JURCIC
25/14 CHAUVEL ST
CAMPBELL ACT 2612
0420 320 120

Lab Number:
Customer Reference Number:
Site:

79751286

DAVID JURCIC
BORE WATER
BORE WATER

Sample Type:
Sample Notes:
Date and Time of Collection:
Date and Time of Testing:
Collected By:
Tested:

14/04/09,1420
16/04/09,0930
The Client
As Received

TESTS	RESULTS	UNITS
pH	6.8	
Conductivity	970	us/cm
Sodium	75	mg/Litre
Potassium	1.8	mg/Litre
Calcium	89	mg/Litre
Magnesium	48	mg/Litre
Chloride	64	mg/Litre
Nitrate	<0.1	mg/Litre (Not Detected)
Sulphate	68	mg/Litre
Aluminium	<0.1	mg/Litre (Not Detected)
Lead	<0.01	mg/Litre (Not Detected)
Copper	<0.01	mg/Litre (Not Detected)
Iron (total)	1.2	mg/Litre

The results are outside the National Health and Medical Research Guidelines for drinking water quality in Australia.
See Iron result. Please refer to fact sheet for Iron.
The above results indicate this water is suitable for animal drinking.

Phosphate	<0.1	mg/Litre	(Not Detected)
-----------	------	----------	----------------

Signed: *David Jurcic* Date: 20/05/09



CERTIFICATE OF ANALYSIS

W0905827
[]

DAVID JURCIC
25/14 CHAUVEL ST
CAMPBELL ACT 2612
0420 320 120

Lab Number:
Customer Reference Number:
Site:

79751286

Sample Type:
Sample Notes:
Date and Time of Collection:
Date and Time of Testing:
Collected By:
Tested:

DAVID JURCIC
BORE WATER
BORE WATER

14/04/09,1420
16/04/09,0930
The Client
As Received

TESTS

RESULTS

Sodium absorption ratio = 1.6.

Signed:  Date: 20/05/09